GENERATING SET GE CURSOR 250E

PRELIMINARY



PERFORMANCES								
RATINGS	50 Hz		60 Hz					
	kVA	kW	kVA	kW				
PRIME	250	200	280	224				
STAND-BY	275	220	305	244				

Ratings in accordance with ISO $8528\,$ - Standard reference conditions : 25° C air inlet temperature ; $1000\,$ mbar ; $30\%\,$ relative humidity - Power factor $0.8\,$.

STAND-BY POWER

CE

Applicable for supplying emergency electrical power for the duration of the utility power outage.

No overload capability is available for this rating.

PRIME POWER

Applicable for supplying electrical power in lieu of commercially purchased power. Prime power is the maximum power available at variable load for an unlimited running time.

A 10% overload capacity is available for governing purposes only.

TECHNICAL DATA									
Engine model		CURSOR 78TE 1	Frequency		50 Hz	60 Hz			
N° of cylinders		6 in line	Fuel consumption*	l/h	43	52			
Total displacement	liters	7.8	* medium consumption according to PRP (ISO 8528-1)						
Aspiration		turbocharged aftercooled							
Cooling system		liquid	Available voltages	V	110/190 to				
Lube oil consumption	<	0.1% of fuel consumption			220/380 to 254/440 (50 Hz 220/380 to 277/480 (60 Hz				
Generating set dimensions ($(L \times W \times H)$	mm 2900 x 935 x 1650	Dry weight with standard accesso	ries kg	~ 20!	50			



STANDARD CONFIGURATION

I. ENGINE DRIVE

IVECO heavy duty diesel engine. Performances in accordance with ISO 8528, G3 class.

2. COOLING SYSTEM

Radiator and pusher fan dimensioned for tropical climates. The radiator is mounted on the base frame to avoid vibrations coming from the engine and is equipped with adequate security protection guards.

3. FILTRATION SYSTEM

The engine is equipped with: dry air filter complete of security element, cartridge fuel filters and oil filter. All filters have replaceable cartridges.

4. EXHAUST SYSTEM

Industrial application exhaust silencers are supplied on request.

5. ELECTRICAL SYSTEM

24 Volt system with battery charging alternator. Starter motor. High performance maintenance free lead acid battery (on request). Battery rack mounted on the generating set base frame.

6. ALTERNATOR

Single bearing synchronous brushless alternator, four poles, mechanical protection degree IP21 and H class insulation. Standard connections: 12 terminals - 9 leads reconnectable. Tropical climates impregnation; on request, humid and corrosive climates treatment. All alternators are equipped with electronic voltage regulator and meet the following standards:

IEC34, CEI2-3, BS4999-5000, VDE0530, EN60034-1, NF51-100, CSA C22-2, OVE M10, NEMA MG1-22.

7. MOUNTING ARRANGEMENT

7.1 Base Frame

The complete generating set is mounted on a modern design and high quality steel fabricated base frame, bended, painted with epoxy coating. In the catch all base frame are located the fuel tank and the batteries. Anti vibration pads are fitted between engine-alternator and base frame ensuring complete vibration isolation of rotating assemblies.

7.2 Coupling

Engine and alternator are directly coupled. The engine flywheel is coupled to the alternator rotor by means of flexible disks.

8. FUEL SYSTEM

Steel sheet fuel tank is provided on the base frame. The fuel tank is equipped with a visual fuel level indicator. Oversized fuel tanks and special certified fuel tanks with automatic refill are available on request.

9. CONTROL PANEL

Manual and Automatic control panels are available in different configurations (see specific brochure).

10. OPTIONS

Generating set can be supplied with different options to meet the specific requirements of the customer.

II. DOCUMENTATION

A full set of operation and maintenance manuals are provided with each unit.

12. FACTORY TESTS

Generating set is subject to a strict load test before delivery. A test certificate can be provided on request.

13. QUALITY STANDARDS

Iveco Aifo gensets meet the following requirements:

89/336/CEE as amended by 92/31/ CEE and 93/68/CEE;

73/23/CEE as amended by 93/68/CEE;

98/37/CE as amended by 98/79/CE.

IVECO AIFO and 2HE are fully accredited ISO 9001 companies.

14. WARRANTY

Local distributor

Generating set is guaranteed for a period of 12 months from the start up date or 18 months from date of shipment whichever occurs earlier. Extended warranty is available on request.

blication P4B048017E - 10/02 ecifications subject to change withour istrations may include optional equip



Iveco Aifo and 2H Energy are companies of the Iveco-Engine Business Unit.

Iveco Aifo S.p.A. V.Ie Dell'Industria, 15/17 20010 Pregnana Milanese MI - Italy Phone +39 02 935101 - Fax +39 02 93590029 Internet: http://www.iveco.com